

COLUMBUS CONSOLIDATED GOVERNMENT

Georgia's First Consolidated Government



FINANCE DEPARTMENT PURCHASING DIVISION

1111 First Avenue, P. O. Box 1340
COLUMBUS, GEORGIA 31902-1340
706-225-4087 | www.columbusga.gov

October 19, 2026

ADDENDUM No. DRAFT DRAGONFLY TRAIL – RIVER ROAD SEGMENT (S.R. 219) RFB No. 27-0006

Use the form provided in the solicitation to acknowledge receipt of this addendum. Failure to do so may result in your submittal being deemed non-responsive and not receiving further consideration for award.

Vendors are informed that the above subject solicitation is hereby modified, corrected, or supplemented as specified, described and set forth in this Addendum:

I. DUE DATE EXTENSION

**The due date for this RFP has been extended.
Proposals are due Wednesday, October 28, 2026, no later than 5:00 PM.**

II. QUESTION(S)/RESPONSE(S)

Question 1: Looking over the project specifications in the Supplementary and Special Provisions document, we cannot find any information on the proposed Bridge Sign Item No. 636-5102. From the drawings, we cannot figure out what to quote, how many signs, what size, etc? Could you please provide us with more information for this line item?
TRAIL SIGN MATL 0.25 ALUM, DIRECT PRINT, PER DETAILS (BRIDGE SIGN) 65 SF

Response: Information regarding bridge signage is located on SM-04. The bridge sign is to follow special provision Section 636 – Trail Signage. Contractor is to include all mounting hardware in bid.

Question 2: Does this project require tree removal?

Response: It is contractor's responsibility to verify existing condition of the site and include all demolition, clearing, tree removal to base bid under Line Item 210-0100 General Conditions.

Question 3: What is the strength of the required for concrete abutment and concrete decking?

Response: Concrete abutments should be 3,000psi GDOT standard class A. Decking will be

per the bridge designer requirements.

Question 4: Is it acceptable for the handrail top rail to be HSS3x2x3/16 ?

Response: Yes, HSS3x2x3/16 is acceptable.

Question 5: Is it acceptable for the handrail verticals to be HSS2x2x3/16?

Response: Yes, HSS3x2x3/16 is acceptable.

Question 6: We've received addendum 4. It mentions updated drawings and an updated SOV; however, they have not been added to the project Dropbox. A screenshot of the Dropbox can be found below. Please let us know how we can access these changes.

Additionally, the addendum states, "to indicate that your company has received this addendum on the appropriate form". Which form is this referring to?

Response: Updated SOV (Schedule of Values – Excel spreadsheet) has been added to the DropBox link.

See page IB-8 of the bid package to indicate receiving addenda numbers.

Question 7: Does this bid need to be submitted electronically?

Response: Yes. Instructions are included in the City's RFB document which is posted: <https://columbusga.gov/finance/bid-opportunities>.

Question 8: You mention on addendum #4, Response #2, so see "revised drawing sheets CP-04, S-1.0, and S-1.1 reflecting changes. But there are no revised drawings attached to this addendum. When can we get a copy of these updated plans files?

Response: Revised items are not attached to the addendum. They are located in the DropBox.

Question 9: You mention on addendum #4, Response #7 "please see line item 670-9710 "Relocate Existing Fire Hydrant" in updated SOV. Where is this SOV located at and how can we get a copy of it?

Response: The SOV (Schedule of Values – Excel spreadsheet) is available in the DropBox.

Question 10: You mention on addendum #4, Response #16 "Geotechnical report ... dropbox link." This information is not available on your dropbox link. Where is this Geotechnical Report located at and how can we get a copy of it?

Response:

Question 11: What is the estimated start date for this project?

Response:

Question 12: What are the lane closure restrictions?

Response:

Question 13: What is anticipated start date

Response:

III. ACKNOWLEDGEMENT

Indicate that your company has received this Addendum on the appropriate form and include with electronic response. **Failure to acknowledge receipt of this addendum may render your response “Incomplete”.**

**Andrea J. McCorvey
Purchasing Manager**

